



- NOTES**
1. CONNECT TO CITY DISTRIBUTION MAIN APPROX. 190M EAST OF SITE.
  2. 50MM TAP OR 110 X 50MM TEE, ROTATED DOWN 45°; RUN PIPE UNTIL IT IS AT 10CM DEPTH, PLACE 45° BEND TO MAKE PIPE HORIZONTAL AND RUN PIPE AT 10CM DEPTH TO BUILDING; 110MM PIPE IS 40 CM BELOW GRADE.
  3. OFFSET SEPTIC AND WATER LINES BY 0.5M WHERE PARALLEL.
  4. AT BURIED SEPTIC/WATER CROSSINGS, ALWAYS RUN THE SEWER BELOW WATER LINE; WHEREVER THE CLEARANCE < 1M BETWEEN THE TWO PIPES, ENCASE THE CROSSING WITH CONCRETE.

DATE ISSUED: **MAY 2007**  
 PROJECT: **5424**  
 SCALE: **1:100**  
 SHEET NUMBER: **P-2**

**THE LORD'S HOUSE - PASSY, SENEGAL**  
**PLUMBING**  
**UPPER FLOOR**